


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 10104 / 30.09.2010**

NUMBER	10104	DATE	30 / 09 / 2010
---------------	--------------	-------------	-----------------------

Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	SINGLE SASH WINDOW WITH ONE FIXED ELEMENT TILT / TURN HARDWARE FOR PVC GROOVE
Material:	ALUMINIUM
System :	E – 45 Thermo



1290 x 2210mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class E1050
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C4

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPAPOPOULOU
LABORATORY MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL