



IRCCOS S.c.a r.l.

Istituto di Ricerca e certificazione per le Costruzioni Sostenibili

Test Laboratory Notified in accordance with Regulation (UE) No. 305/2011

TEST REPORT

Number:

1994-CPR-RP1294

(Issued in replacement of the Test Report n. 1994-CPR-RP1158 of 20/05/2015)

Issuing date:

3 February 2016

Applicant:

**Etem Bulgaria S. A.
Ilientzi 119A, Sofia, 1220, Bulgaria**

Tested product:

Double vent with one fixed glazing

Trade name: "E50"

(cf. description)

Executed tests:

Air permeability

Watertightness

Resistance to wind load

Normative References:

EN 14351-1:2006+A1:2010

EN 1026:2000 EN 12207:1999


EN 1027:2000 EN 12208:1999

EN 12211:2000 EN 12210:1999

The report is done up of 45 pages, including any annex, and can be reproduced only integrally.

*Sede legale Via Achille Grandi 17 – 21017 Samarate (VA) - Tel. 0331 594628 - www.irccos.com
Cap. Soc. € 111.526 I.V. - C.F. e P. Iva 05159630960 - Reg. Imprese Milano 05159630960 - R.E.A. 1799766
Società partecipata dal Consiglio Nazionale delle Ricerche*

- 9 Resume of classes assigned on the basis of the results of the tested sample of a double vent sliding door-standard version- with trade name “E50”, according to TR n° 1994-CPR-RP1294, issued on 03-02-2015 to Etem Bulgaria S. A..

Scheme of the tested sample	Test	Test standard	Classification standard	Obtained Class	Cf. § TR
 <p>The diagram shows a cross-section of a double vent sliding door. It consists of two sashes (left and right) within a casement. Numbered points 1-7 indicate specific locations: 1 and 6 are at the top of the casement; 2 and 7 are at the bottom of the sashes; 3 and 4 are on the left sash; 5 is on the right sash. Labels include 'F' for the frame, 'W=WIDTH OF CASEMENT' at the bottom, and 'HEIGHT OF SASH' and 'H=HEIGHT OF CASEMENT' on the right side. An arrow indicates the sliding direction.</p>	Air permeability	EN 1026:2000	EN 12207:1999	class 4	§ 7.2.1
	Watertightness	EN 1027:2000	EN 12208:1999	class 8A	§ 7.3.1
	Resistance to wind load	EN 12211:2000	EN 12210:1999	class B2	§ 7.4.5

10 Limitations

This Test Report does not represent either an evaluation the suitability of use or a certificate of product conformity. The results obtained refer exclusively to the samples tested.

Technical Operators

Katia Joti

Matteo Tarrotto

The Technical Director

Giuseppe Caravita

-----End of the Test Report No. 1994-CPR-RP1294-----